



June 21, 1996

Pacific Seismic Products, Inc.  
Attn: Mr. Bill Keller  
233 East Avenue H8  
Lancaster, CA 93535

Dear Mr. Keller:

Your application for certification of the Seismic Actuated Electrical Switch Assembly, Model 510, has been approved contingent on the following stipulations:

1. Certification is based on material supplied with the application which include, but not limited to, test data showing compliance with State Building Standards Commission, Standard number 12-23-1, drawings, specifications and service.
2. Compliance with section 1378 of Title 21 for the Division of the State Architect (DSA) label. Final makeup and printing of tags, notices and box labels is to be provided to the State Architect with the production model for affirmation per 1378 (e). Enclosed is a photo ready DSA label.
3. Quality control inspections shall be conducted quarterly per Title 21, and at least one such inspection shall occur in each production run of less than three months duration.
4. Verified inspection service reports are due within 30 days after inspection.
5. If any changes occur in the manufacturing of product, company ownership, or changes as noted in Title 21, Section 1371 through 1385, DSA is to be notified in writing within thirty (30) days or the certification becomes invalid.
6. This certification will remain in force until rendered invalid by the State Architect.
7. The following number has been assigned to you and must appear on certification label: application number 41 and item number 109.

If you have any questions, please call me at (916) 445-0584.

Sincerely,

H.P. Campbell, Principal Structural Engineer  
Seismic Program  
Division of the State Architect

HPC:dla

cc: Joel McDonald, Principal Architect, Special Programs, DSA